।। श्री अग्रसेनो विजयते ।।

श्री अग्रवाल समाज प्रभातीदेवी प्रसादीलाल पब्लिक स्कूल

(श्री अग्रवाल समाज, मदनगंज-किशनगढ़ के पूर्ण स्वामित्व की संचालित संस्था)

खोड़ा गणेशजी रोड़, मदनगंज-किशनगढ़ (राज.) 305801

पत्रांक SASPPPS/2026/Water-9/101 दिनांक 12/08/2026

To,
The Ex. en.
Public Health Engineering Department,
Kishangarh

Sub. – Request for issuing safe drinking water and sanitation certificate.

Respected sir / ma'am,

With the reference to above mention subject I Dr. E. Rajesh, Principal, Shree Agarwal Samaj Prabhatidevi Prasadilal Public school, Kishangarh need safe drinking water certificate for CBSE affiliation purpose. I am Submitting report of chemical examination of water and report of bacteriological examination of water issued by Sup. Chemist regional Lab. Ajmer.

I request you to issue the safe drinking water certificate on the basis of attached certificates.

Thanks

12-8-26

Dr. E. Rajesh

Principal
Shree Agarwal Samaj
Prabhatidevi Prasadilal
Public school, Kishangarh

PRINCIPAL
SHREE AGARWAL SAMAJ PRABHATI DEVI
PRASADI LAL PUBLIC SECONDARY SCHOOL
MADANGANJ-KISHANGARH

Attached

1. Report Of Chemical Examination Of Water
2. Report Of Bacteriological Examination Of Water

अध्यक्ष	उपाध्यक्ष	सचिव	सह सचिव	कोषाध्यक्ष
श्याम सुन्दर अग्रवाल	राजेन्द्र अग्रवाल	शिवचरण गोयल	मुरलीधर अग्रवाल	अतुल अग्रवाल
9352010028	9829073181	9829045076	9829070565	9829071005

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY, AJMER (Raj)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No.Lab/Tech./26-27/ 823 Sample was not Collected by Laboratory

Date: 10.08.2026

To,

Principal
Shree Agrwal Samaj Prabhati Devi Prasadi Lal
Public Senior Secondary School Khoda Ganesh
Road Kishangarh

District:- Ajmer
Tehsil:- Kishangarh

Not for Legal Purpose

Reference : Your Letter No :- 99 Dated :- 03.08.2026

Sample Collected by :-. Sardar Singh Rawat School Employee

Date of Receipt :- 03.08.2026

Lab Sample No.		IS10500:2012		P-9
Source :		Desirable Limit as per IS10500:2012	Permissible Limit in absence of alternate source	RO Treated (Tube Well)
Source Location:				Shree Agrwal Samaj Prabhati Devi Prasadi Lal Public Senior Secondary School Khoda Ganesh Road
Town / City				Madanganj, Kishangarh
Date of Collection→				03.08.2026
Date of Examination→				03.08.2026
Test Parameter↓				**Results↓**
1	pH Value	6.5 - 8.5	No Relaxation	7.08
2	Turbidity (NTU)	1	5	0.1
3	Colour (Hazen Units)	5	15	Nil
4	Odour	Agrreable		Agrreable
5	Total Alkalinity (as $CaCO_3$) mg/l	200	600	40
6	Total Hardness (as $CaCO_3$) mg/l	200	600	30
7	Chlorides as Cl^- mg/l	250	1000	20
8	Fluorides as F^- *mg/l*	1.0	1.5	0.1
9	Nitrate as NO_3^- *mg/l*	45	No Relaxation	0.2
10	Total Dissolved Solids(T.D.S.) *mg/l*	500	2000	108
11	Residual Chlorine	0.2	1.0	Nil
		Applicable only when water is Chlorinated		

Note: *1. The sample was not collected by this laboratory.*
2. This Report is not for legal Purpose.

6/8/2026

(Dr Archana Mathur)
Superintending Chemist
P.H.E.D.Regional Lab.,Ajmer

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, REGIONAL LABORATORY, AJMER
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No. Lab/Tech(Bact)/2026-27/ 824 **Sample was not Collected by Laboratory** Date 10.8.2026

To,

Principal
Shree Agarwal Samaj Prabhati Devi Prasadilal Public Sec School
Khoda Ganesh Road, Madanganj-Kishangarh

District :- Ajmer
Tehsil :- Kishangarh

Reference : Your Letter No.- Nil Dated 31.07.2026
Sample Collected by :- Sh Hemraj Prajapat School Employee

Sr. No;	Lab Sample No.	Date & Time of Collection	Date of Examination	City / Village	Source & Location	Residual Chlorine (mg/L)	Total Coliform Organism MPN/100 ml.
1	B- 3	03.08.2026 10.15 AM	03.08.2026	Kishangarh	R.O.Treated (Tubewell) Shree A.S.P.P. Public School	-	Nil

Remarks

Satisfactory:- Lab Sample No. B- 3
Unsatisfactory:- Nil

Note 1. The sample was not collected by this laboratory
2. This Report is not for legal Purpose.

6/8/2026
(Dr. Archana Mathur)
Superintending Chemist
P.H.E.D. Regional Lab.,Ajmer